



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PERFORMANCE P T INC		REINSPECTION DATE Not Specified	INSPECTOR Britney Nguyen	DATE 5/31/2016
LOCATION 10431 COMMERCE ST A, REDLANDS, CA 92374		PERMIT EXPIRATION 6/30/2016	IDENTIFIER: None	
TIME IN 1:57 PM	TIME OUT 2:30 PM	FACILITY ID FA0016641	RELATED ID PR0038009	PE 3620
		SERVICE: 001 - INSPECTION - ROUTINE		
		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU		
		ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

87
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K502 Water Quality - Critical – Disinfectant level **⚠ CRITICAL ⚠**

POINTS 5	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65529	Inspector Comments: Measure the free chlorine to be high. Please maintain the free chlorine 1.0 ppm with a max at 10.0 ppm.
---------------------------	--	---

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

36K506 Water Quality - Critical – Water pH 7.2 to 7.8 **⚠ CRITICAL ⚠**

POINTS 5	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65530	Inspector Comments: Measured the pH at 6.7. Please maintain the pH at 7.2 to 7.8.
---------------------------	--	---

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PERFORMANCE P T INC	DATE 5/31/2016
LOCATION 10431 COMMERCE ST A, REDLANDS, CA 92374	INSPECTOR Britney Nguyen

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the No Diving sign missing from the spa. Please provide the No Diving safety sign.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K562 Skimmers - Pool skimming systems

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the weir panel missing. Please replace the weir. Observed debris in the skimmer basket. Please clear the basket.
	Not In Compliance	
	Violation Reference - CCR - 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

36K572 Maintenance – Pool shell cleanliness; slime and algae

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed black mold on a few tile in the pool shell. Please clean the pool water while the pool is in use.
	Not In Compliance	
	Violation Reference - HSC - 65533	

Violation Description: (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> PERFORMANCE P T INC	<small>DATE</small> 5/31/2016
<small>LOCATION</small> 10431 COMMERCE ST A, REDLANDS, CA 92374	<small>INSPECTOR</small> Britney Nguyen

Total # of Images: 0