



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|--|--|--------------------------|--|--|
| FACILITY NAME PACIFIC PALMS MOBILEHOME PARK | | DATE 6/18/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 12/31/2015 |
| LOCATION 2727 E PACIFIC ST, SAN BERNARDINO, CA 92410 | | | INSPECTOR Sierra Clayborn | |
| MAILING ADDRESS PO BOX 11927, SANTA ANA CA 92711 | | | IDENTIFIER: Office Pool | |
| TIME IN 12:45 PM | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME OUT 1:25 PM | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE | |
| FACILITY ID FA0008848 | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |
| RELATED ID PR0015681 | | | PE 3620 | |




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 94 |
| volume (gal) | 34,000 |
| area (sq ft) | 1,000 |
| occupancy | 50 |

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K504 Water Quality – Non-Critical – Disinfectant level low

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed free chlorine at 0.11ppm in pool. |
| | Not In Compliance | Maintain free chlorine between 2.0ppm and 10ppm when using cyanuric acid. |
| | Violation Reference - HSC - 65529 | *Corrected during inspection to 1.0ppm. |

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

36K518 Water Quality – Cyanuric acid concentration

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed cyanuric acid exceeding 100ppm. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65530 | |

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|------------------------------|
| FACILITY NAME PACIFIC PALMS MOBILEHOME PARK | DATE 6/18/2015 |
| LOCATION 2727 E PACIFIC ST, SAN BERNARDINO, CA 92410 | INSPECTOR Sierra Clayborn |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

| | | |
|---|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed the following pool safety signs missing: CPR Capacity of bathers not filled in Modified 911 sign in 1 inch font featuring the name and address of the pool facility and the phone number to the nearest emergency services No Life Guard on Duty sign with the change in the word "Should" to "Shall" |
| | Not In Compliance | |
| | Violation Reference - CCR - 3120B | |
| Provide required safety signs as soon as possible, preferably before next routine inspection. | | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K546 Equipment – Non-Critical - Water treatment system operation

| | | |
|--------------------|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed flow meter bobbin stuck in column. Clean/repair. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65525 | |

Violation Description: The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

36K556 Equipment – Plumbing labeled

| | | |
|--------------------|--------------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Provide labels for direction of flow of water through recirculation system on plumbing by next routine inspection. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|------------------------------|
| FACILITY NAME PACIFIC PALMS MOBILEHOME PARK | DATE 6/18/2015 |
| LOCATION 2727 E PACIFIC ST, SAN BERNARDINO, CA 92410 | INSPECTOR Sierra Clayborn |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K560 Equipment – Waste water

| | | |
|-----------------------------------|--------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed no air gap available between backwash drainage pipe and opening to sewer. |
| | Not In Compliance | Provide an air gap of at least 1 inch to prevent back siphonage. |
| Violation Reference - CCR - 3141B | | |

Violation Description: There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system.

Material cleaned from filters and backwash water from any recirculation system shall be disposed in a manner that is acceptable to the local wastewater agency and will not create a nuisance. Backwash water shall not be returned to a pool. Pipes carrying wastewater from pools including pool drainage and backwash from filters shall be installed as an indirect waste in accordance with the requirements of Chapter 8 of the California Plumbing Code.

The backwash from a diatomaceous earth filter shall discharge into a separation tank that has been installed to collect the waste diatomaceous earth mixture. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

36K562 Skimmers - Pool skimming systems

| | | |
|-----------------------------------|--------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed wier gate missing in pool. |
| | Not In Compliance | Replace. |
| Violation Reference - CCR - 3136B | | |

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

36K576 Maintenance – Operation/Incident records

| | | |
|-----------------------------------|--------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed no records available for daily water chemistry testing. |
| | Not In Compliance | Water chemistry must be tested and recorded daily. |
| Violation Reference - HSC - 65523 | | |

Violation Description: The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0