



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|--|---------------------|--------------------------|--|-------------------|
| FACILITY NAME PACIFIC HIGH SCHOOL | | DATE 5/6/2015 | REINSPECTION DATE Next Routine | PERMIT EXPIRATION |
| LOCATION 1020 PACIFIC ST, SAN BERNARDINO, CA 92404 | | | INSPECTOR Chris Nwadike | |
| MAILING ADDRESS 1020 PACIFIC ST, SAN BERNARDINO, CA 92404 | | | IDENTIFIER: Shallow Pool | |
| | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME IN 2:02 PM | TIME OUT 2:59 PM | FACILITY ID FA0004188 | RELATED ID PR0013903 | PE 3603 |
| | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE | |
| | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |




RECREATIONAL HEALTH - Public School Pool / Spa

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

95
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | 81.0 |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K502 Water Quality – Critical – Disinfectant level ⚠ CRITICAL ⚠

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 5 | Compliance Date: Not Specified | Inspector Comments: Observed chlorine level at 0.36ppm. Maintain chlorine level between 2.0ppm and 10.0ppm. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65529 | |

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0