



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME WRIGHTWOOD COUNTRY CLUB		DATE 8/19/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2015
LOCATION 1387 ORIOLE RD, WRIGHTWOOD, CA 92397			INSPECTOR Melissa Nano	
MAILING ADDRESS PO BOX 1986, WRIGHTWOOD CA 92397			IDENTIFIER: Spa	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 11:36 AM	TIME OUT 12:01 PM	FACILITY ID FA0007359	RELATED ID PR0013734	PE 3622
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Initial Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




98

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

POINTS 1	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	Maintain a pH level between 7.2 and 7.8.
	Violation Reference - HSC - 65530	Observed pH level at 8.2.

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	Repair/tighten hand rail at entry steps.
	Violation Reference - HSC - 65535	Observed loose.
		Repair/replace flow meter.
		Observed stuck.

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments

NOTE:

New construction or spa/pool remodels are required to obtain and post the new "Active Diarrhea" sign. Existing pools/spas are not required.

If there are any questions, please contact Environmental Health Services or Melissa Nano at (800) 442-2283.



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME WRIGHTWOOD COUNTRY CLUB	DATE 8/19/2015
LOCATION 1387 ORIOLE RD, WRIGHTWOOD, CA 92397	INSPECTOR Melissa Nano

Signature(s) of Acknowledgement

A handwritten signature in blue ink that reads "A. Cabral".

NAME: Antoinette Cabral

TITLE: Manager

Total # of Images: 0