



## RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME KFC		DATE 9/3/2015	REINSPECTION DATE 9/03/2015	PERMIT EXPIRATION
LOCATION 12125 MARIPOSA RD, VICTORVILLE, CA 92392			INSPECTOR Robert Adams	
MAILING ADDRESS 12441 HESPERIA RD #47 VICTORVILLE, CA 92395			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 025 - PLAN REVIEW	
TIME IN 3:30 PM	TIME OUT 3:45 PM	FACILITY ID FA0004496	RELATED ID SR0069987	PE 1767
			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
			ACTION: 55 - PLANS APPROVED	

### RETAIL FOOD PLAN CHECK - PInCk PEP Minor 0-1,499 SqFt

#### 17K986 Plans - Plan Review Approved

Compliance Date: Not Specified  
Not In Compliance

Inspector Comments: Eplans approved to install anew pack line to replace the existing pack line. No other scope is approved. See report for conditions.

Reference - HSC - 114380

**Description:** Thank you for your plan submittal.Plans have been approved with the following corrections.This approval does not constitute authority to violate any provision of the related codes, ordinances, or regulations, nor does it prevent further correction of errors found on the plan or with installation upon field inspection. All construction must conform to these approved plans. Alterations or changes to these plans must have review and written approval by the Plan Check Section of Environmental Health Services prior to construction.

#### 17K088 Equipment - General - ANSI

Compliance Date: Not Specified  
Not In Compliance

Inspector Comments: See below.

Reference - HSC - 114130(b)

**Description:** All new and replacement food-related and utensil related equipment shall be certified or classified for sanitation by an American National Standards Institute (ANSI) accredited certification program (NSF, ITS, ETL, EPH, UL Sanitation or CSA).

#### 17K246 Plans - Submittal - Remodel - Final

Compliance Date: Not Specified  
Not In Compliance

Inspector Comments: Call for inspection once the pack line is installed. 800-442-2283.

Reference - Reference Number - SBC Policy

**Description:** Final construction must be approved by this Department prior to putting the remodeled areas into operation.

#### 17K247 Plans - Submittal - Remodel - Finishes

Compliance Date: Not Specified  
Not In Compliance

Inspector Comments: See below.

Reference - HSC - 114380

**Description:** Existing finishes are subject to evaluation by this Department. This determination will be made at the time of the preliminary field inspection. Finishes found not to be in compliance with current code requirements will not be accepted.

#### 17K685 Plumbing - General - Air gap

Compliance Date: Not Specified  
Not In Compliance

Inspector Comments: See below.

Reference - HSC - 114193(a)

**Description:** All steam tables, ice machines and bins, food preparation sinks, warewashing sinks, display cases, walk-in refrigeration units, and other similar equipment that discharge liquid waste shall be drained by means of indirect waste pipes, and all wastes drained by them shall discharge through an air gap into a floor sink.

#### 17K842 Plans - Submittal - Remodel - Protection

Compliance Date: Not Specified  
Not In Compliance

Inspector Comments: See below.

Reference - HSC - 113980

**Description:** Strict protective measures must be taken to prevent the contamination of food or food contact surfaces during the course of remodeling. Failure to do so may result in the closure of the food facility until all remodeling activities have been completed.



**RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

FACILITY NAME KFC	DATE 9/3/2015
LOCATION 12125 MARIPOSA RD, VICTORVILLE, CA 92392	INSPECTOR Robert Adams

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0