




Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PRINCETON VILLAGE			DATE 9/2/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2016
LOCATION 1141 W PRINCETON , ONTARIO, CA 91762				INSPECTOR Nicole Walker	
MAILING ADDRESS 675 W FOOTHILL BLVD, CLAREMONT CA 91711			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Pool SERVICE: 008 - INSPECTION - ATTEMPTED RESULT: 00 - NOT APPLICABLE ACTION: 00 - NOT APPLICABLE		
TIME IN 10:45 AM	TIME OUT 10:55 AM	FACILITY ID FA0008510	RELATED ID PR0014478	PE 3620	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	48
volume (gal)	17,325
area (sq ft)	420
occupancy	21

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Will attempt an inspection at a later date.

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

An attempt to inspect the pool at the above location has failed due to inaccessibility to the property.

Section 116053 of California Health and Safety Code state, "For the purposes of this article; any health officer or any inspector of the state department may at all reasonable times enter all parts of the premises of a public swimming pool to make examination and investigation to determine the sanitary condition and whether this article of the rules and regulations are being violated."

To rectify this situation, send the appropriate keys to allow this department to all pool areas, including the equipment room and the code for the front gate.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0