



RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME VILLAGE ON THE GREEN APARTMENTS				REINSPECTION DATE Not Specified	INSPECTOR Bennetta Betbadal	DATE 10/19/2015
LOCATION 9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA, CA 91730				PERMIT EXPIRATION	IDENTIFIER: None	
TIME IN 8:30 AM	TIME OUT 9:00 AM	FACILITY ID FA0014399	RELATED ID SR0069944	PE 3716	SERVICE: 126 - PLAN CHECK FIELD INSPECTION RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH PLAN CHECK - Plnck Pool Minor Remodel - all

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

37K509 Plans - Final Inspection

Compliance Date: Not Specified **Inspector Comments:** Final inspection, authorized to reopen the spa.
Not In Compliance **Scope of work:** repplaster.
Reference - Reference Number - SBC Policy

Description: Final inspection hereby gives facility approvals to open.

Overall Inspection Comments

Chlorine: 3.5 PPM
PH: 7.4

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0