



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|--|---------------------|--------------------------|--|---------------------------------|
| FACILITY NAME YMCA CAMP ROUND MEADOW | | DATE 7/23/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 12/31/2015 |
| LOCATION 41011 JENKS LAKE RD, ANGELUS OAKS, CA 92305 | | | INSPECTOR Yvette Velasco | |
| MAILING ADDRESS 625 NEW HAMPSHIRE AV, LOS ANGELES CA 90005 | | | IDENTIFIER: Pool | |
| <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME IN 2:40 PM | TIME OUT 3:25 PM | FACILITY ID FA0006901 | RELATED ID PR0006566 | PE 3620 |
| | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE | |
| | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




97

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | 85.0 |
| observed flow (gpm) | 250 |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed pH in the pool at 6.8. |
| | Not In Compliance | Ensure to maintain pH at 7.2-7.8. |
| | Violation Reference - HSC - 65530 | |

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|-----------------------------|
| FACILITY NAME YMCA CAMP ROUND MEADOW | DATE 7/23/2015 |
| LOCATION 41011 JENKS LAKE RD, ANGELUS OAKS, CA 92305 | INSPECTOR Yvette Velasco |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

| | | |
|--------------------|--|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed signs for site information and emergency facility not provided on site. Ensure to provide all appropriate signs in the pool area. |
| | Not In Compliance Violation Reference - CCR - 3120B | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K566 Lighting – Requirements

| | | |
|--------------------|--|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed light fixture on the left side of the pool (from entrance) non-functional. Ensure to replace or repair light as soon as possible. |
| | Not In Compliance Violation Reference - CCR - 3115B | |

Violation Description: Pools shall have underwater and deck lighting such that lifeguards or other persons may observe, without interference from direct and reflected glare from the lighting sources, every part of the underwater area and pool surface, all diving boards or other pool appurtenances.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Gabriel Lamette
TITLE:

Total # of Images: 0