



Public Health
Environmental Health Services


www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME HAMPTON INN & SUITES			DATE 7/31/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 2710 LENWOOD RD, BARSTOW, CA 92311				INSPECTOR Michelle Saltis	
MAILING ADDRESS 1806 E MAIN ST, MESA AZ 85203			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Pool SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 01 - NO FURTHER ACTION REQUIRED		
TIME IN 3:58 PM	TIME OUT 4:12 PM	FACILITY ID FA0015644	RELATED ID PR0020794	PE 3620	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	65
volume (gal)	23,350
area (sq ft)	760
occupancy	38

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A reinspection was conducted today, 7/31/15, to follow up on compliance of the gate to self close/latch. Observed gate to self latch/close and in good working condition.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: mike higby
 TITLE: maintenance
 Total # of Images: 0