



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME RAINBO BEACH		REINSPECTION DATE Not Specified		INSPECTOR Jeffrey Benedict	DATE 5/19/2016
LOCATION 3520 NEEDLES HWY, NEEDLES, CA 92363				PERMIT EXPIRATION 8/31/2016	IDENTIFIER: Pool
TIME IN 12:45 PM	TIME OUT 2:00 PM	FACILITY ID FA0005021	RELATED ID PR0016007	PE 3620	SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

99
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	115
required flow (gpm)	No Data
volume (gal)	29,000
area (sq ft)	550
occupancy	27

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K990 Survey Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: <hr/>
	Not In Compliance	
	Violation Reference - SBCC - SBC Policy	

Description: A survey inspection was conducted on this date.

36K550 Equipment – Chemical/Disinfectant feeders

POINTS 1	Compliance Date: Not Specified	Inspector Comments: There are no chlorine tablets in the automatic chlorinator. The chlorinator is to be operable to provide a constant chlorine residual in the pool.
	Not In Compliance	
	Violation Reference - CCR - 3133B, 3134B	

Violation Description: The chemical feeder equipment shall:

1. Be maintained and repaired according to manufacturers' specifications; and
2. Be constructed with an adjustable output rate device to permit repeated adjustments without loss of output rate accuracy and adjusted by an automatic chemical monitoring and control system that regulates, at a minimum, pH and disinfectant; and
3. Meet the applicable requirements established by the most recent NSF/ANSI performance standard.

All feeders shall be capable of supplying not less than the equivalent of 3 pounds (1 kg) of 100 percent available chlorine per day per 10,000 gallons (37,850 L) of pool water capacity.

Overall Inspection Comments

water clarity - good

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> RAINBO BEACH	<small>DATE</small> 5/19/2016
<small>LOCATION</small> 3520 NEEDLES HWY, NEEDLES, CA 92363	<small>INSPECTOR</small> Jeffrey Benedict

NAME: SNA
TITLE:

Total # of Images: 0