



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>CALIFORNIA INN</b>		REINSPECTION DATE <b>Not Specified</b>		INSPECTOR <b>Ahn Tran</b>	DATE <b>8/15/2016</b>
LOCATION <b>1431 E MAIN ST, BARSTOW, CA 92311</b>				PERMIT EXPIRATION <b>5/31/2017</b>	IDENTIFIER: Pool
TIME IN <b>11:05 AM</b>	TIME OUT <b>11:35 AM</b>	FACILITY ID <b>FA0008643</b>	RELATED ID <b>PR0015697</b>	PE <b>3620</b>	SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

<b>Ideal</b>
<b>In Compliance</b>
<b>Not in Compliance</b>



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	95
volume (gal)	30,000
area (sq ft)	800
occupancy	40

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K502 Water Quality - Critical – Disinfectant level** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>5</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> The free chlorine residual concentration was at 01 ppm. Adjust so that there is 2.0 ppm free chlorine concentration.
	Not In Compliance	
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

**36K516 Water Quality – Non-Critical – Water clarity**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> observed cloudy water in the pool at this time.
	Not In Compliance	
	Violation Reference - HSC - 65527	

**Violation Description:** The pool operator shall maintain clear pool water while the public pool is in use. The pool operator shall close the public pool if the bottom of the pool at the maximum depth is not clearly visible from the deck. The pool operator shall not reopen the public pool for use until the pool water is clean and clear, and the bottom of the pool at the maximum depth is clearly visible from the deck. If the bottom of the pool is not visible 48 hours following inspection and closure by the enforcing agent, the enforcing agent may order the pool drained.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**



Public Health  
Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)  
[www.SBCounty.gov/dph/dehs](http://www.SBCounty.gov/dph/dehs)

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME CALIFORNIA INN	DATE 8/15/2016
LOCATION 1431 E MAIN ST, BARSTOW, CA 92311	INSPECTOR Ahn Tran

NAME:  
TITLE:

Total # of Images: 0