



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|--|----------------------------|---------------------------------|--|---------------------------------------|
| FACILITY NAME AMBER TREE CONDOMINIUMS | | DATE 8/20/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 6/30/2016 |
| LOCATION 1735 E WASHINGTON ST, COLTON, CA 92324 | | | INSPECTOR John Babalola | |
| MAILING ADDRESS PO BOX 51128, RIVERSIDE CA 92517 | | | IDENTIFIER: Pool | |
| <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME IN 4:00 PM | TIME OUT 4:41 PM | FACILITY ID FA0008678 | RELATED ID PR0014343 | PE 3620 |
| | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE | |
| | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




89

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | No Data |
| observed flow (gpm) | 0 |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | 0 |

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

| | | |
|---------------------------|---------------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: The pH level is observed at 7.0 at the time of inspection. Maintain between 7.2 and 7.8. Ideal is 7.4 - 7.6. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65530 | |

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.



Public Health Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|-----------------------------------|
| FACILITY NAME AMBER TREE CONDOMINIUMS | DATE 8/20/2015 |
| LOCATION 1735 E WASHINGTON ST, COLTON, CA 92324 | INSPECTOR John Babalola |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

| | | |
|---------------------------|--|--|
| POINTS 1 | Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3120B | Inspector Comments: Provide the phone number for the nearest emergency services and the name and address of the facility at the pool side. None observed. Provide a sign at the entrance area of the pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water at the pool side. None observed. |
|---------------------------|--|--|

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

36K554 Equipment - Pressure/Vacuum gauge requirements

| | | |
|---------------------------|---|---|
| POINTS 1 | Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3125B.2 | Inspector Comments: Replace the damaged influent pressure gauge. |
|---------------------------|---|---|

Violation Description: A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 ¼ times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.

36K562 Skimmers - Pool skimming systems

| | | |
|---------------------------|--|--|
| POINTS 1 | Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3136B | Inspector Comments: Replace the missing skimmer weir gates. |
|---------------------------|--|--|

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.



Public Health Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|---|-----------------------------------|
| FACILITY NAME AMBER TREE CONDOMINIUMS | DATE 8/20/2015 |
| LOCATION 1735 E WASHINGTON ST, COLTON, CA 92324 | INSPECTOR John Babalola |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K564 Structure – Depth and safety markers

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: No break line observed between the shallow and the deep (8 ft) areas of the pool. Provide the break line. Note: This is a continuous violation! |
| | Not In Compliance | |
| | Violation Reference - CCR - 3110B | |

Violation Description: The water depth shall be clearly marked at the following locations:

1. Maximum depth; and
2. Minimum depth; and
3. Each end; and
4. Both sides at the shallowest and deepest part of the pool; and
5. At the break in the bottom slope between the shallow and deep portions of the pool (see also Section 3109B.3); and
6. Along the perimeter of the pool at distances not to exceed 25 feet (7620 mm).

For pool water depths 6 feet (1830 mm) or less no diving markers with the universal symbol of no diving, which is a red circle with a slash through it superimposed over the image of a diver, shall be installed on the deck directly adjacent to the depth markers.

36K564 Structure – Depth and safety markers

| | | |
|---------------------------|-----------------------------------|----------------------------|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: |
| | Not In Compliance | |
| | Violation Reference - CCR - 3110B | |

Violation Description: The water depth shall be clearly marked at the following locations:

1. Maximum depth; and
2. Minimum depth; and
3. Each end; and
4. Both sides at the shallowest and deepest part of the pool; and
5. At the break in the bottom slope between the shallow and deep portions of the pool (see also Section 3109B.3); and
6. Along the perimeter of the pool at distances not to exceed 25 feet (7620 mm).

For pool water depths 6 feet (1830 mm) or less no diving markers with the universal symbol of no diving, which is a red circle with a slash through it superimposed over the image of a diver, shall be installed on the deck directly adjacent to the depth markers.

36K582 Maintenance - Public pool site maintenance

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Secure the unstable hand rails. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K582 Maintenance - Public pool site maintenance

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Fill in the missing capacity number. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|--|----------------------------|
| FACILITY NAME AMBER TREE CONDOMINIUMS | DATE 8/20/2015 |
| LOCATION 1735 E WASHINGTON ST, COLTON, CA 92324 | INSPECTOR John Babalola |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K582 Maintenance - Public pool site maintenance

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Replace/repair the non-functional flow meter. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K582 Maintenance - Public pool site maintenance

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Replace/repair the non-functional skimmer. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K582 Maintenance - Public pool site maintenance

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Replace the faded flow direction labels in the equipment room. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: SNA
TITLE:

Total # of Images: 0