



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PARK AVE APARTMENTS		DATE 5/19/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 5/31/2014
LOCATION 2871 N PARK AV, SAN BERNARDINO, CA 92404			INSPECTOR Anies Kondoker	
MAILING ADDRESS 216 S YNEZ AV UNIT B, MONTEREY PARK CA 91754			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 10:57 AM	TIME OUT 11:10 AM	FACILITY ID FA0008847	RELATED ID PR0013847	PE 3620
RESULT: 00 - NOT APPLICABLE				
ACTION: 00 - NOT APPLICABLE				

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: _____
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

No access to the pool enclosure.
Manager is not on site. Called the number posted on manager's door but no answer.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0