





RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME RAINTREE GARDENS			DATE 9/11/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 18125 BELLFLOWER, ADELANTO, CA 92301				INSPECTOR Michelle Saltis	
MAILING ADDRESS 631 S OLIVE ST #860, LOS ANGELES CA 90014			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Pool SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVIC RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 01 - NO FURTHER ACTION REQUIRED		
TIME IN 2:26 PM	TIME OUT 2:49 PM	FACILITY ID FA0008631	RELATED ID PR0013611	PE 3620	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	78
volume (gal)	28,000
area (sq ft)	936
occupancy	46

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K993 Re-Reinspection

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: A re-reinspection was conducted to follow up on the compliance of the pool perimeter fencing.

Observed pool fencing fixed and in good working condition.
Pool facility is now in compliance of pool fencing.

Observed water clarity clear.

Description: Billable re-reinspection conducted at the time to determine compliance from prior inspection.

Overall Inspection Comments

Facility is now in compliance with pool fencing.

Signature(s) of Acknowledgement

NAME: liciana velazquez
TITLE: property manager

Total # of Images: 0