



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>FIESTA HILLS MHP</b>		DATE <b>5/5/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>4/30/2015</b>
LOCATION <b>2692 HIGHLAND AV, HIGHLAND, CA 92346</b>			INSPECTOR <b>Marilyn Krichbaum</b>	
MAILING ADDRESS <b>3850 ATLANTIC AV 39, HIGHLAND CA 92346</b>			IDENTIFIER: Pool	
TIME IN <b>4:28 PM</b>			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT <b>5:30 PM</b>			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
FACILITY ID <b>FA0012125</b>			ACTION: 14 - PERMIT SUSPD / FACILITY CLOSED FENCI	
RELATED ID <b>PR0013502</b>			PE <b>3620</b>	




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**100**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	60
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K502 Water Quality – Critical – Disinfectant level** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed a low chlorine level of .38ppm. Immediately add chlorine. Maintain a chlorine level of 2.0ppm.
	Not In Compliance	
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

**36K540 Enclosure – Critical – Gates and doors self-closing and self-latching** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed that the west gate did not completely self latch. Immediately repair the gate so that it self closes and self latches. Pool is closed till this violation is corrected. Call Marilyn at 1-800-442-2283 for reinspection. Will reinspect 5-6-15.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

At the end of the inspection, located the manager onsite and told him to immediately secure the gate.

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

**36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed a high ph level of 7.9. Lower the ph level so that it is 7.2-7.8.
	Not In Compliance	
	Violation Reference - HSC - 65530	

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME FIESTA HILLS MHP	DATE 5/5/2015
LOCATION 2692 HIGHLAND AV, HIGHLAND, CA 92346	INSPECTOR Marilyn Krichbaum

#### 36K556 Equipment – Plumbing labeled

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: Completely label and identify the flow of the water thru the pool recirculation system on the pool piping by using arrows.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

#### 36K582 Maintenance - Public pool site maintenance

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: Repair the loose handrails.
	Not In Compliance	
	Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

#### 36K588 Restrooms - Toilet facilities/Showers

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: Still observed that the showers in both restrooms were full of items and could not be used as noted on prior inspection reports. Remove the items out of the showers and also in the womens restroom so they can be use
	Not In Compliance	
	Violation Reference - CCR - 3116B	

**Violation Description:** Separate toilet facilities shall be provided for each sex. One toilet shall be provided for every 60 women or less and one toilet plus one urinal for every 75 men or less. One lavatory shall be provided for every 80 pool users.

Shower and dressing facilities shall be provided for users of a pool.

#### Overall Inspection Comments

No summary comments have been made for this inspection.

#### Signature(s) of Acknowledgement

*Discussed with mgr*

NAME:

TITLE:

Total # of Images: 0