



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PARK VISTA		DATE 4/17/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 1031 S PALMETTO , ONTARIO, CA 91761			INSPECTOR Veronica Martinez	
MAILING ADDRESS PO BOX 5022, UPLAND CA 91785			IDENTIFIER: Pool	
TIME IN 4:28 PM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 4:50 PM			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
FACILITY ID FA0008422			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	
RELATED ID PR0014563			PE 3620	


RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

90
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	77
volume (gal)	27,540
area (sq ft)	864
occupancy	30

36K995 Permit - Suspension ⚠️ CRITICAL ⚠️

POINTS NA	Compliance Date: Not Specified	Inspector Comments: The pool is ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). Contact EHS office at 1(800) 442-2283 to schedule a reinspection to reinstate the health permit.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level ⚠️ CRITICAL ⚠️

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed chlorine level above 11ppm. The pool is ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). Contact EHS office at 1(800) 442-2283 to schedule a reinspection to reinstate the health permit.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed facility without life ring. Provide.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K452 Maintenance - Flow Rate/Turnover Time

POINTS 2	Compliance Date: Not Specified	Inspector Comments: No access to pump area. Flow Rate/ Turnover Time unable to be determined. Provide access to pump area.
	Not In Compliance	
	Violation Reference - CCR 24 - 3124B	

Violation Description: The recirculation system shall have the capacity to provide a complete turnover of pool water in:

1. One-half hour or less for a spa pool;
2. One-half hour or less for a spray ground;
3. One hour or less for a wading pool;
4. Two hours or less for a medical pool; and
5. Six hours or less for all other types of public pools.

The variation in flow of an operating recirculation system shall be such as not to reduce the flow below 75 percent of the rate required.



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PARK VISTA	DATE 4/17/2015
LOCATION 1031 S PALMETTO , ONTARIO, CA 91761	INSPECTOR Veronica Martinez

36K466 Structure - Pool Shell

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed plaster of pool with visible etching. Ensure pool shell is smooth and easily cleaned. Repair.
	Not In Compliance	
	Violation Reference - CCR - 3108B	

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

Overall Inspection Comments

Free Chlorine: >11ppm
 pH: 7.4
 Cyanuric acid: 25.2ppm

Signature(s) of Acknowledgement

NAME: No signature available
 TITLE:

Total # of Images: 0