



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>QUALITY INN</b>		DATE <b>7/17/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>1/31/2016</b>
LOCATION <b>1750 S WATERMAN AV, SAN BERNARDINO, CA 92408</b>			INSPECTOR <b>Veronica Vazquez</b>	
MAILING ADDRESS <b>1750 S WATERMAN AV, SAN BERNARDINO, CA 92408</b>			IDENTIFIER: Pool	
TIME IN <b>9:50 AM</b>	TIME OUT <b>10:24 AM</b>	FACILITY ID <b>FA0006654</b>	RELATED ID <b>PR0014802</b>	PE <b>3620</b>
			SERVICE: 001 - INSPECTION - ROUTINE	
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 03 - REINSPECTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.



**92**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	120
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	26

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K524 Safety – Critical – Electrical hazards; GFCI** **⚠ CRITICAL ⚠**

**POINTS**  
**5**

Comply by: **7/24/2015**  
 Not In Compliance  
 Violation Reference - **HSC - 116049**

**Inspector Comments:** Immediately repair/replace ground fault circuit interrupter (GFCI) for pool light. Observed two GFCI in equipment room and none turned pool light off.  
 Will reinspect. Operator is unsure which GFCI belongs to pool. Operator will contact pool service operator.

**Violation Description:** The design and installation of all underwater lighting systems, operating at more than 15 volts, supplied from a branch circuit either directly or by way of a transformer, shall be installed in a public swimming pool so that there is no shock hazard with any likely combination of fault conditions during normal use, and shall comply with both of the following requirements:

- (1) An approved ground-fault circuit interrupter shall be installed in the branch circuit that supplies all fixtures operating at more than 15 volts.
- (2) Only approved underwater lighting fixtures shall be used and no lighting fixtures shall be installed for operations at more than 150 volts between conductors.



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>QUALITY INN</b>	DATE <b>7/17/2015</b>
LOCATION <b>1750 S WATERMAN AV, SAN BERNARDINO, CA 92408</b>	INSPECTOR <b>Veronica Vazquez</b>

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K527 Safety – Safety signs

<b>POINTS</b> <b>1</b>	<b>Compliance Date: Not Specified</b>	<b>Inspector Comments:</b> Provide sign e) The number of nearest emergency services and name/address of pool facility.
	<b>Not In Compliance</b>	
	<b>Violation Reference - CCR - 3120B</b>	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with ""CAUTION"" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

#### 36K528 Safety – Safety equipment

<b>POINTS</b> <b>1</b>	<b>Compliance Date: Not Specified</b>	<b>Inspector Comments:</b> Observed two life rings without attached rope. Immediately attach rope to life rings. Rope must be able to span the width of pool.
	<b>Not In Compliance</b>	
	<b>Violation Reference - HSC - 65540</b>	Observed one rope attached to pool fence. Operator removed rope from pool fence and attached to one of two life rings.

**Violation Description:** Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

#### 36K582 Maintenance - Public pool site maintenance

<b>POINTS</b> <b>1</b>	<b>Compliance Date: Not Specified</b>	<b>Inspector Comments:</b> Ensure to remove glass bottle from skimmer. Observed one glass bottle in pool skimmer. Operator removed glass bottle.
	<b>Not In Compliance</b>	
	<b>Violation Reference - HSC - 65535</b>	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME QUALITY INN	DATE 7/17/2015
LOCATION 1750 S WATERMAN AV, SAN BERNARDINO, CA 92408	INSPECTOR Veronica Vazquez

**Overall Inspection Comments**

Will reinspect ground fault circuit interrupter (GFCI).

Call Veronica Vazquez at (800) 442-2283 with questions.

**Signature(s) of Acknowledgement**

NAME:

TITLE:

Total # of Images: 0