



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME COMFORT SUITES HOTEL				DATE 5/15/2013	SIGNATURE
LOCATION 2571 FISHER BL, BARSTOW, CA 92311				REINSPECTION DATE 11/15/2013	PERMIT EXPIRATION 1/31/2014
MAILING ADDRESS 15051 LEFFINGWELL RD UNIT 201, WHITTIER CA 90604				REHS Kathy Taylor	
FA # FA0016636	PR # PR0022377	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 12:05 PM	TIME OUT 12:35 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	50
volume (gal)	18,240
area (sq ft)	608
occupancy	30

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Maintain pool pH no lower than 7.2; testing today at 7.0 but corrected on site. pH now 7.5 after addition of soda ash.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Cyanuric acid level high in pool due to high chlorine level. Lower cyanuric acid by draining a little water out of pool and adding fresh.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K430 Safety - Equipment/First Aid Kit

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65539

Inspector Comments: Firmly attach a rope on life ring long enough to span pool width. Ring present but without rope.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Repair flowmeter so it will accurately show pool turnover rate. Turnover rate for this pool is at least

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Repair flowmeter so it will accurately reflect correct flow; this pool requires a minimum flow rate of 50 gallons per minute. Unable to read flow on flowmeter.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME COMFORT SUITES HOTEL	DATE 5/15/2013	SIGNATURE
LOCATION 2571 FISHER BL, BARSTOW, CA 92311		REHS Kathy Taylor

Overall Inspection Comments

Pool chlorine level slightly high at 12 ppm; maintain a chlorine level of no higher than 10 ppm. High chlorine levels can affect bather comfort and safety.

pH corrected at inspection time and adjusted to 7.6.

Provide directional arrows on piping in pump room to show direction of water flow.

New signs are required for next year as there are some changes in the size of lettering and wordage. This Department can provide a flyer to you for next years changes.

Thank you

Photo Attachments:

No Photo Attachments