



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME CAMP PAIVIKA				DATE 10/21/2013	SIGNATURE
LOCATION 600 PLAYGROUND DR, CRESTLINE, CA 92325				REINSPECTION DATE Not Specified	PERMIT EXPIRATION
MAILING ADDRESS 5045 VAN BUREN BL RIVERSIDE, CA 92503				REHS Bennetta Betbadal	
FA # FA0006909	PR # Not Specified	SR # SR0060602	CO # Not Specified	PE 3712	PROGRAM IDENTIFIER: None
TIME IN 10:00 AM	TIME OUT 1:53 PM	CONTACT Not Captured			SERVICE: 025 - PLAN REVIEW
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 55 - PLANS APPROVED

RECREATIONAL HEALTH PLAN CHECK - PLNCK POOL NEW 1,000-UP SQFT

37K980 Plans - Plan Review Approved

Compliance Date: Not Specified **Inspector Comments:** Plan is approved for a new pool in a camp.
Not In Compliance
Violation Reference - HSC
 This pool is approved with a handicap ramp and an above ground pool cover.
 Pool will have one shower and one restroom on site and additional restrooms and showers will be at the adjacent buildings within 77 to 220 feet of the pool.

Violation Description: Plans have been approved and this correction sheet is a part of the approved plans.

37K013 Ancillary - Finishes - Floor

Compliance Date: Not Specified **Inspector Comments:**
Not In Compliance
Violation Reference - CCR 24 - 3115B.3

Violation Description: Floors shall have a hard nonabsorbent surface, such as concrete, ceramic tile or other approved material. Concrete floors shall be sealed with an approved sealer; paints are unacceptable. Floors shall be slip resistant and shall be sloped not less than one quarter (1/4) inch per foot to floor drains. The floor shall be continuously covered up the wall at least five (5) inches; the cove to be an integral part of the floor.

37K034 Decking - General

Compliance Date: Not Specified **Inspector Comments:** 3112B.3 a bull-nosed coping or cantilevered decking of reinforced concrete, or material equivalent in strength and durability, with rounded slip resistant edges shall be provided. The overhang for either bull-nosed coping or cantilevered decking shall not exceed 2 inches (51 mm) or be less than 1 inch (25 mm) and shall not exceed 2 1/2 inches (64 mm) in thickness.
Not In Compliance
Violation Reference - CCR 24 - 3111B
 Ensure to use approved coping.

Violation Description: A handhold of bullnose coping or cantilevered decking is required.

37K038 Decking - Pool

Compliance Date: Not Specified **Inspector Comments:**
Not In Compliance
Violation Reference - CCR 24 - 3113B

Violation Description: A continuous and unobstructed four (4) foot minimum width deck that is made of slip resistant, nonabrasive concrete or like material must be provided flush with the top of the pool and extend completely around the pool.

37K062 Enclosure - General

Compliance Date: Not Specified **Inspector Comments:** Doors, openable windows, or gates of living quarters or associated private premises shall not be permitted as part of the pool enclosure.
Not In Compliance
Violation Reference - CCR 24 - 3118B

Violation Description: The pool shall be enclosed by one (1) of the following: a fence, portion of a building, wall or other approved durable enclosure. Doors, openable windows, or gates of living quarters or associated private premises shall not be permitted as part of the pool enclosure.

37K068 Enclosure - General - Climbable

Compliance Date: Not Specified **Inspector Comments:**
Not In Compliance
Violation Reference - CCR 24 - 3118B.1

Violation Description: Planters or other structures shall not be permitted within five (5) feet of the enclosure.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME CAMP PAIVIKA	DATE 10/21/2013	SIGNATURE
LOCATION 600 PLAYGROUND DR, CRESTLINE, CA 92325	REHS Bennetta Betbadal	

37K084 Equipment - Disinfection - Size

Compliance Date: Not Specified

Inspector Comments: Chlorinator should be able to provide 18 lb of chlorine per day.

Not In Compliance

Violation Reference - CCR 24 - 3133B.1

Violation Description: The disinfectant feeder shall be capable of supplying not less than the equivalent of 3 pounds of chlorine per day per 10,000 gallons of pool water capacity.

37K278 Structure - Stairs

Compliance Date: Not Specified

Inspector Comments: Ensure to provide slip-resistance tiles on the edge of pool steps.

Not In Compliance

Violation Reference - CCR 24 - 3110B.3

Violation Description: Each step of a stair must have the same dimensions, with a tread of not less than 12 inches, except for a curved top step which must be 18 inches in width at the widest point. Risers must be uniform and must not exceed 12 inches in height.

37K481 Enclosure - General – Stone

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Violation Reference - CCR 24 - 3118B

Violation Description: Stone columns, walls, etc. that are part of the pool enclosure (fence) must be a minimum 5 feet tall, smooth and non-climbable

37K482 Enclosure - Laundry and Exercise Rooms

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Violation Reference - CCR 24 - 3118B.2

Violation Description: If non-ancillary rooms (such as laundry and/or exercise rooms) open into the pool area, their doors shall be self-closing and self latching.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CAMP PAIVIKA	DATE 10/21/2013	SIGNATURE
LOCATION 600 PLAYGROUND DR, CRESTLINE, CA 92325	REHS Bennetta Betbadal	

Mechanical Pool Cover Requirements: (Cover manufacture: cover pools.com)

- 1-Permanent or safety type pool covers must be not obstruct the deck in any way nor interfere with the coping requirements and be ANSI approved.
- 2- Pool cover must meet current American Society for Testing and Materials (ASTM) requirements for safety covers.
- 3- The cover must be installed and used according to manufacturer's instructions.
- 4- Provisions must be made for the stair handrail and deep-end ladder so that they do not interfere with the cover. (The removable rail with locking pin is not approved.)
- 5- All retracting mechanisms and their associated housing, must be located a minimum of 4 feet back from the pool edge.
- 6- Tracks located on the deck surface must be designed to be slip-resistant and not exceed a height of 5/8 inch. The track must be of contrasting color to the deck surface. The track which crosses the 4 foot deck area to the retracting mechanism must be painted a contrasting color of red or yellow.
- 7- the track must be installed far enough away from the coping so as not to interfere with handhold of the coping. Screws used to secure the track to the deck must be countersunk. (Tracks which are installed under the coping handhold are not approved.)
- 8- The activating switch must be installed so that the operator has a clear view of the entire pool.
- 9- The activating switch must be a "dead-man" type switch where the cover will stop once the key is released.
- 10- The mechanism must be designed so that the cover will return to the open position if it encounters an obstruction while closing.
- 11- Camp owner/ management shall provide DEHS with a written verification that only an on-site responsible person, will have keys to operate the pool cover mechanism. Children should not be allowed to operate the pool cover mechanism.
- 12- Cover must be completely removed when pool is open for use.

Pool Area: 1980 sq ft
Pool Capacity: 60,000 gallons
Pool Occupancy: 99 bathers
Pool Turnover Rate: 167 gpm

Pump: (2) Pentair WFE-6 1 1/2HP 100 gpm (total 200 gpm)
Filter: (2) Pentair Quad 100 100 gpm (total 200 gpm)
Drain and equalizer covers: Paramount SDX (200 gpm floor, 192 gpm wall)
Skimmers: (4) Pentair SP90-2
Chlorinator: Pentair AT-8
Flow Meter: (2) Blue & White F-300
Separation Tank: (20 Pentair SC-20 2"

Main Drain Suction Line: 3" 138 gpm at 6 fps
Skimmer Suction Line: 3" 138 gpm at 6 fps
Return Line: 2 1/2" 149 gpm at 10 fps
Fill Line: 3/4"

Photo Attachments:
No Photo Attachments