



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>SIERRA POINTE APARTMENTS</b>				DATE <b>7/9/2014</b>	SIGNATURE	
LOCATION <b>1439 N LILAC AV, RIALTO, CA 92376</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2014</b>	
MAILING ADDRESS <b>8150 COTTONWOOD AV, FONTANA CA 92335</b>				REHS <b>Syed Farook</b>		
FA # <b>FA0003552</b>	PR # <b>PR0013793</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Spa SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>4:15 PM</b>	TIME OUT <b>4:45 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**84**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**

**CRITICAL**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Spa has been closed due to high chlorine level and low pH.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K404 Water Quality - Critical - High Disinfectant Level**

**CRITICAL**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed greater than 10 ppm chlorine in spa.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K406 Water Quality - Critical - pH High/Low**

**CRITICAL**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pH below 7.0.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed cyanuric acid above 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>SIERRA POINTE APARTMENTS</b>	DATE <b>7/9/2014</b>	SIGNATURE
LOCATION <b>1439 N LILAC AV, RIALTO, CA 92376</b>	REHS <b>Syed Farook</b>	

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed address sign, capacity sign and spa hours sign blank.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**36K430 Safety - Equipment/First Aid Kit**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no rope on safety ring.
	Not In Compliance	
	Violation Reference - CCR - 65539	

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed water level high.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments