385 N Arrowhead Ave, San Bernardino, CA 92415 | Phone: 800.442.2283 Fax: 909.387.4323
www.SBCounty.gov
www.SBCounty.gov/dph/dehs

SAN BERNARDINO COUNTY

Public Health
Environmental Health Services

RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME				REINSPECTION DATE	INSPECTOR	DATE
YEAST N FLOUR				Not Specified	Jane Troy	3/17/2016
LOCATION				PERMIT EXPIRATION	IDENTIFIER: None	
231 N EUCLID AV, ONTARIO, CA 91762					SERVICE: 045 - PLAN CHECK- BILLABLE INSPECTION SER	
TIME IN	TIME OUT	FACILITY ID	RELATED ID	PE	RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
11:00 AM	11:50 AM	Not Specified	SR0069532	1769	ACTION: 01 - NO FURTHER ACTION REQUIRED	

RETAIL FOOD PLAN CHECK - PlnCk PEP New 1,500-5,999 SqFt

17K985 Plans - Final Inspection

Compliance Date: Not Specified
Not In Compliance
Reference - HSC

Inspector Comments: Final inspection conducted today for a new food facility. As this is the fifth construction inspection, this inspection will be billable. Approval is hereby given to open for business upon completion of the corrections below and upon final approval from City of Ontario.

Description: Final inspection hereby gives facility approvals to open pending the listed violations are corrected as specified.

17K031 Construction - Employee Facilities

Compliance Date: Not Specified
Not In Compliance
Reference - CCDEH Guidelines - CCDEH

Inspector Comments: Relocate lockers from unfinished back area into food storage area. As lockers are small, 12X12-inch, provide wall mounted coat hooks beside lockers.

Description: Lockers must be installed on six (6) inch high, easily cleanable legs, cantilevered off the wall, or on a minimum four (4) inch high continuously coved curb or platform. L-angle legs are not acceptable.

17K045 Construction - Plan - Mop Rack

Compliance Date: Not Specified
Not In Compliance
Reference - HSC - 114282

Inspector Comments: Ensure that a mop/broom rack is installed on the wall above or beside the mop sink.

Description: Provide a mop rack in the mop sink area.

17K383 Vermin - Air curtain - Delivery Doors

Compliance Date: Not Specified
Not In Compliance
Reference - CCDEH Guidelines - CCDEH

Inspector Comments: Install air curtain as discussed over doorway leading into building hallway. Air curtain must be microswitch activated and door it is over must be self closing.

Description: Delivery doors shall be equipped with a microswitch activated air curtain device that delivers an air velocity of at least 750 feet per minute, measured three (3) feet above the floor. The curtain of air shall cover the entire width of the door. For delivery doors that are wider than four (4) feet, the air curtain must produce an air velocity of at least 1600 feet per minute, as measured three (3) feet above the floor.

17K403 Structure - Walls - General Requirement

Compliance Date: Not Specified
Not In Compliance
Reference - HSC - 114259

Inspector Comments: Finish pony wall between hallway leading to restroom and front prep/cooking area, so wall is smooth and easy to clean.

Description: The walls and ceilings of all rooms shall be of a durable, smooth, nonabsorbent, and easily cleanable surface.

17K806 Permit - Food Handler Cards

Compliance Date: Not Specified
Not In Compliance
Reference - SBCC - 33.0409(b)

Inspector Comments: Ensure all employees obtain an approved food handler card within 14 days of hire. The facility must retain these cards onsite.

Description: Applicability. Except as provided herein, no person shall work or allow the employment of any person as a food handler within this jurisdiction except when such food handler possesses an unexpired, unsuspended, unrevoked food handler card or a certificate after passing an approved and accredited food safety certification exam as described in õ 113947.1 of the Health and Safety Code (food safety certificate). Food handlers are exempt from this requirement for 14 calendar days following the date of employment if working under the supervision of a person holding an unexpired, unsuspended, unrevoked food safety certificate.

Overall Inspection Comments

385 N Arrowhead Ave, San Bernardino, CA 92415 | Phone: 800.442.2283 Fax: 909.387.4323

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

SAN BERNARDINO COUNTY

Public Health
Environmental Health Services

RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME	DATE
YEAST N FLOUR	3/17/2016
LOCATION	INSPECTOR
231 N EUCLID AV, ONTARIO, CA 91762	Jane Troy

Install approved "slim foot" ceramic tile coved base or metal coved base with a 3/8-inch radius cove around Big Dipper grease recovery device.

Application for health permit was completed and facility will be invoiced for annual permit fees.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0